

20210476.5/1107A/R1/AZ

27/03/2024

Selleys Pty Ltd
1 Gow Street
PADSTOW NSW 2211

Attn: Heidi Stevens

Selleys Consulting & Product Development - Selleys Fireblock PA (suitable for use in wall systems rated up to Rw 67) - Acoustic Opinion

This letter provides our opinion regarding the acoustic performance of Selleys Fireblock PA sealant and the proposed changes in formulation. This opinion is a continuation of the previous opinion provided by this office (ref: 2011001/2907A/R2/MS, dated 29th July 2011).

It is understood that the current uncured (theoretical) specific gravity of the sealant is 1.526 and will change to a theoretical 1.498 based on the new formulations.

Based on this difference, there would be no measurable difference in performance, and the previous opinion provided by this office (ref: 2011001/2907A/R2/MS, dated 29th July 2011) remains unchanged. On this basis, Selleys Fireblock PA is suitable for use in wall systems up to R_w 67.

We trust this information is satisfactory. Please contact us should you have any further queries.

Yours faithfully,

Acoustic Logic Pty Ltd
Adrian Zappia
MAAS

SYDNEY
9 Sarah St
MASCOT NSW 2020
(02) 8339 8000ABN 98 145 324 714
www.acousticlogic.com.au

The information in this document is the property of Acoustic Logic Pty Ltd 98 145 324 714 and shall be returned on demand. It is issued on the condition that, except with our written permission, it must not be reproduced, copied or communicated to any other party nor be used for any purpose other than that stated in particular enquiry, order or contract with which it is issued.